

District Health Department No. 4



Alpena County

100 Woods Circle
Suite 200
Alpena, MI 49707
(989) 356-4507
Fax (989) 356-3529

Cheboygan County

Doris E. Reid Center
825 S. Huron St.
Suite 1
Cheboygan, MI 49721
(231) 627-8850
Fax (231) 627-9466

Montmorency County

P.O. Box 183
12519 State Street
Atlanta, MI 49709
(989) 785-4428
Fax (989) 785-2217

Presque Isle County

106 E. Huron St.,
Suite A
Rogers City, MI 49779
(989) 734-4723
Fax (989) 734-3866

www.dhd4.org

Administrative Services

Alpena County

Office

DHD No. 4 EH-188b

SEASONAL PUBLIC DRINKING WATER SUPPLY SAMPLING REQUIREMENTS

Attached are the Seasonal Public Drinking Water Supply Sampling Requirements and a calendar that outlines your sampling requirement quarters for 2019.

Failure to collect and submit samples in these quarters will result in District Health Department No. 4 (DHD4) contacting you for establishing an alternative for meeting these sampling requirements. Under the Revised Total Coliform Rules (RTCR) a single violation (failure to monitor) will result in an increase to a **monthly** monitoring frequency. This change strengthens the need to assure compliance is met for all drinking water monitoring for the public water supply at your facility.

Please save the attached calendar and sampling requirements below. If you have any questions or concerns, please contact DHD4 or visit our website at www.dhd4.org for more information.

TYPE II SEASONAL WATER SAMPLING INSTRUCTIONS

Each seasonal facility is required to conduct Approved Start-Up Procedures and return a completed Start-Up Certification Form to the Local Health Department (see enclosed procedures/form). *Opening the facility without Health Department approval may put people at risk and subject the facility owner to compliance action by DHD4.*

- ❖ **BEFORE the facility opens for the season, conduct approved start-up procedures and collect 2 separate start-up bacteria samples a minimum of 24 hours apart (both must be non-detect).** Start-up samples do not count for your routine quarterly bacteria samples!
- ❖ **BACTERIA – ONE ROUTINE** sample must be collected **EACH quarter** during the **operational period.**
- ❖ **PARTIAL CHEMICAL/NITRATE – ONE ROUTINE** sample must be collected **any time** during the **operational period.**

*****BE SURE TO WRITE THE WATER SUPPLY SERIAL NUMBER (WSSN) FOR THE FACILITY ON SAMPLE REQUEST FORMS!*****

Please see the attached Northern Michigan Regional Laboratory calendar for holidays or closures that may limit the days samples are accepted. They will accept water samples for analysis Monday, Tuesday, and Wednesday. Please call the Northern Michigan Regional Laboratory at 989-732-1794 should you have any questions or concerns whether they are open and accepting samples.